



6 White Dove Ct. Lakewood NJ 08701
Tel- (732)668-9078 Fax – (732)358-0168
Cert # 00407A Cert # 00430E

05/13/2021

To whom it may concern:

Re: Water Samples at 150 Pierce Dr. Somerset, NJ

We have sampled the drinking water at the above property for lead and copper. Please note the Federal Action Level for lead is 15 ug/l (ppb), and for copper is 1,300ug/l (ppb).

The results were found to be below the action level.

Thank you very much.

Sincerely,



Joseph Perlstein



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Joseph Perlstein
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

5/12/2021

Phone: (732) 668-9078
Fax: (732) 358-0168

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 4/28/2021. The results are tabulated on the attached data pages for the following client designated project:

150 Pierce Dr. Somerset NJ

The reference number for these samples is EMSL Order #012104352. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104352

CustomerID: LBPA78

CustomerPO:

ProjectID:

Attn: **Joseph Perlstein**
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Phone: (732) 668-9078
 Fax: (732) 358-0168
 Received: 4/28/2021 09:55 AM

Project: 150 Pierce Dr. Somerset NJ

Analytical Results

Client Sample Description 1 Kindergarten Bath #1 **Collected:** 4/26/2021 8:00:00 AM **Lab ID:** 012104352-0001

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 96 | 5.0 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:03 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:03 |

Client Sample Description 2 Kindergarten Bath #2 **Collected:** 4/26/2021 8:00:00 AM **Lab ID:** 012104352-0002

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 260 D | 25 µg/L | 5/11/2021 VD | 5/11/2021 VD 14:12 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:09 |

Client Sample Description 3 Water Fountain by Room #221 - #1 **Collected:** 4/26/2021 8:00:00 AM **Lab ID:** 012104352-0003

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 400 D | 50 µg/L | 5/11/2021 VD | 5/11/2021 VD 14:13 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:10 |

Client Sample Description 4 Water Fountain by Room #221 - #2 **Collected:** 4/26/2021 8:00:00 AM **Lab ID:** 012104352-0004

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 370 D | 50 µg/L | 5/11/2021 VD | 5/11/2021 VD 14:15 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:12 |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104352

CustomerID: LBPA78

CustomerPO:

ProjectID:

Attn: **Joseph Perlstein**
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Phone: (732) 668-9078
 Fax: (732) 358-0168
 Received: 4/28/2021 09:55 AM

Project: 150 Pierce Dr. Somerset NJ

Analytical Results

Client Sample Description 5
 Elementary Bath Womens Left #1
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0005

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 160 D | 25 µg/L | 5/11/2021 VD | 5/11/2021 VD 14:17 |
| 200.8 | Lead | 1.51 | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:14 |

Client Sample Description 6
 Elementary Bath Womens Left #2
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0006

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 79 | 5.0 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:19 |
| 200.8 | Lead | 1.14 | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:19 |

Client Sample Description 7
 Elementary Mens Bath Right #1
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0007

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 87 | 5.0 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:21 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:21 |

Client Sample Description 8
 Elementary Mens Bath Right #2
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0008

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 61 | 5.0 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:22 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:22 |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

| | |
|-------------|-----------|
| EMSL Order: | 012104352 |
| CustomerID: | LBPA78 |
| CustomerPO: | |
| ProjectID: | |

Attn: **Joseph Perlstein**
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Phone: (732) 668-9078
 Fax: (732) 358-0168
 Received: 4/28/2021 09:55 AM

Project: 150 Pierce Dr. Somerset NJ

Analytical Results

Client Sample Description 9
 Elementary Mens Bath Left #1
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0009

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 58 | 5.0 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:24 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:24 |

Client Sample Description 10
 Elementary Mens Bath Left #2
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0010

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 63 | 5.0 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:26 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:26 |

Client Sample Description 11
 Elementary Womens Bath Right #1
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0011

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 110 D | 10 µg/L | 5/11/2021 VD | 5/11/2021 VD 14:20 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:27 |

Client Sample Description 12
 Elementary Womens Bath Right #1
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0012

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 76 | 5.0 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:32 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:32 |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104352

CustomerID: LBPA78

CustomerPO:

ProjectID:

Attn: **Joseph Perlstein**
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Phone: (732) 668-9078
 Fax: (732) 358-0168
 Received: 4/28/2021 09:55 AM

Project: 150 Pierce Dr. Somerset NJ

Analytical Results

Client Sample Description 13
 Mens Bath Gym Left #1
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0013

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 290 D | 25 µg/L | 5/11/2021 VD | 5/11/2021 VD 14:22 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:34 |

Client Sample Description 14
 Mens Bath Gym Left #2
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0014

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 460 D | 50 µg/L | 5/11/2021 VD | 5/11/2021 VD 14:24 |
| 200.8 | Lead | 1.66 | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:39 |

Client Sample Description 15
 Gym Water Fountain Right #1
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0015

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 170 D | 25 µg/L | 5/11/2021 VD | 5/11/2021 VD 14:25 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:41 |

Client Sample Description 16
 Gym Water Fountain Right #2
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0016

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 160 D | 25 µg/L | 5/11/2021 VD | 5/11/2021 VD 14:27 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:43 |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104352

CustomerID: LBPA78

CustomerPO:

ProjectID:

Attn: **Joseph Perlstein**
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Phone: (732) 668-9078
 Fax: (732) 358-0168
 Received: 4/28/2021 09:55 AM

Project: 150 Pierce Dr. Somerset NJ

Analytical Results

Client Sample Description 17
 Gym Water Fountain Left #1
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0017

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 81 | 5.0 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:44 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:44 |

Client Sample Description 18
 Gym Water Fountain Left #2
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0018

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 86 | 5.0 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:46 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:46 |

Client Sample Description 19
 Womens Gym Left #1
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0019

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 500 D | 50 µg/L | 5/11/2021 VD | 5/11/2021 VD 14:43 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:48 |

Client Sample Description 20
 Womens Gym Left #2
Collected: 4/26/2021 8:00:00 AM
Lab ID: 012104352-0020

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 200 D | 25 µg/L | 5/11/2021 VD | 5/11/2021 VD 14:50 |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 VD 12:49 |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104352

CustomerID: LBPA78

CustomerPO:

ProjectID:

Attn: **Joseph Perlstein**
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Phone: (732) 668-9078
 Fax: (732) 358-0168
 Received: 4/28/2021 09:55 AM

Project: 150 Pierce Dr. Somerset NJ

Analytical Results

Client Sample Description 21 Employee Bathroom #1 **Collected:** 4/26/2021 8:00:00 AM **Lab ID:** 012104352-0021

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 55 | 5.0 µg/L | 5/11/2021 VD | 5/11/2021 13:21 VD |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 13:21 VD |

Client Sample Description 22 Employee Bathroom #2 **Collected:** 4/26/2021 8:00:00 AM **Lab ID:** 012104352-0022

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Copper | 77 | 5.0 µg/L | 5/11/2021 VD | 5/11/2021 13:26 VD |
| 200.8 | Lead | ND | 1.00 µg/L | 5/11/2021 VD | 5/11/2021 13:26 VD |

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



Lead (Pb) Chain of Custody

EMSL Order ID (Lab Use Only):

012104352

EMSL ANALYTICAL, INC.
 3 COOPER STREET
 WESTMONT, NJ 08108
 PHONE: (856) 858-4800
 FAX: (856) 858-3899

| Company : AAA LEAD PROFESSIONALS | | | EMSL-Bill to: <input type="checkbox"/> Same <input type="checkbox"/> Different If Bill to is Different note instructions in Comments** | |
|--|--|--|---|----------------------------------|
| Street: 6 WHITE DOVE CT | | | Third Party Billing requires written authorization from third party | |
| City: LAKEWOOD | State/Province: NJ | Zip/Postal Code: 08701 | Country: | |
| Report To (Name): JOSEPH PERLSTEIN | | Fax #: | | |
| Telephone #: 7326689078 | Email Address: JOSEPHPERLSTEIN@YAHOO.COM | | | |
| Project Name/Number: 150 Perce Dr. Somerset NJ | | | | |
| Please Provide Results: <input type="checkbox"/> Fax <input type="checkbox"/> Email | | Purchase Order: | U.S. State Samples Taken: | |
| Turnaround Time (TAT) Options* - Please Check | | | | |
| <input type="checkbox"/> 3 Hour | <input type="checkbox"/> 6 Hour | <input type="checkbox"/> 24 Hour | <input type="checkbox"/> 48 Hour | <input type="checkbox"/> 72 Hour |
| <input type="checkbox"/> 96 Hour | <input type="checkbox"/> 1 Week | <input checked="" type="checkbox"/> 2 Week | | |
| <small>*Analysis completed in accordance with EMSL's Terms and Conditions located in the Price Guide</small> | | | | |
| Matrix | Method | Instrument | Reporting Limit | Check |
| Chips <input type="checkbox"/> mg/cm ² <input type="checkbox"/> % by wt. | SW846-7000B/7420 or AOAC 974.02 | Flame Atomic Absorption | 0.01% | <input type="checkbox"/> |
| | Air | NIOSH 7082 | Flame Atomic Absorption | 4 µg/filter |
| | NIOSH 7105 | Graphite Furnace AA | 0.03 µg/filter | <input type="checkbox"/> |
| | NIOSH 7300 modified | ICP-AES | 0.5 µg/filter | <input type="checkbox"/> |
| Wipe* <input type="checkbox"/> ASTM <input type="checkbox"/> non ASTM <small>*if no box is checked, non-ASTM Wipe is assumed</small> | SW846-7000B/7420 | Flame Atomic Absorption | 10 µg/wipe | <input type="checkbox"/> |
| | SW846-6010B or C | ICP-AES | 0.5 µg/wipe | <input type="checkbox"/> |
| TCLP | SW846-1311/7420/SM 3111B | Flame Atomic Absorption | 0.4 mg/L (ppm) | <input type="checkbox"/> |
| | SW846-6010B or C | ICP-AES | 0.1 mg/L (ppm) | <input type="checkbox"/> |
| Soil | SW846-7000B/7420 | Flame Atomic Absorption | 40 mg/kg (ppm) | <input type="checkbox"/> |
| | SW846-7421 | Graphite Furnace AA | 0.3 mg/kg (ppm) | <input type="checkbox"/> |
| | SW846-6010B or C | ICP-AES | 1 mg/kg (ppm) | <input type="checkbox"/> |
| Wastewater | SM3111B or SW846-7000B/7420 | Flame Atomic Absorption | 0.4 mg/L (ppm) | <input type="checkbox"/> |
| | EPA 200.9 | Graphite Furnace AA | 0.003 mg/L (ppm) | <input type="checkbox"/> |
| | SW846-6010B or C | ICP-AES | 1 mg/kg (ppm) | <input type="checkbox"/> |
| Drinking Water | EPA 200.9 | Graphite Furnace AA | 0.003 mg/L (ppm) | <input type="checkbox"/> |
| Other: | | Preservation Method (Water): | | |
| Name of Sampler: | | Signature of Sampler: | | |
| Sample # | Location | Volume/Area | Date/Time Sampled | |
| 1 | Kidney garden Bath #1 | | 04/26/12 AM | |
| 2 | " " " #2 | | | |
| 3 | Water fountain by room #221-#1 | | | |
| 4 | " " " " #2 | | | |
| 5 | Elementary Bath women left #1 | | | |
| 6 | " " " " #2 | | | |
| Client Sample #'s | | Total # of Samples: | | |
| Relinquished (Client): | | Date: 04/26/12 | Time: | |
| Received (Lab): | Elefina UPS | Date: 04/28/12 | Time: 9:55 AM | |
| Comments: Lead in water & Copper in water | | | | |

RECEIVED PRESERVED EH 4128

2 X 66 10R 03 6456 7647

(22) EH



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

LEAD (Pb) CHAIN OF CUSTODY

EMSL ORDER ID (Lab Use Only):

012104352

EMSL ANALYTICAL, INC.
200 ROUTE 130 NORTH
CINNAMINSON, NJ 08077
PHONE: (856) 858-4800
FAX: (856) 858-3899

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

| Sample # | Location | Volume/Area | Date/Time Sampled |
|----------|---------------------------------|-------------|-------------------|
| 7 | Elementary mens Bath right #1 | | |
| 8 | " " " " #2 | | |
| 9 | " " " left #1 | | |
| 10 | " " " " #2 | | |
| 11 | Elementary womens Bath right #1 | | |
| 12 | " " " " #2 | | |
| 13 | Mens Bath gym left #1 | | |
| 14 | " " " " #2 | | |
| 15 | gym water Fountain right #1 | | |
| 16 | " " " " #2 | | |
| 17 | " " " left #1 | | |
| 18 | " " " " #2 | | |
| 19 | Womens gym left #1 | | |
| 20 | " " " " #2 | | |
| 21 | Employee Bath room #1 | | |
| 22 | " " " " #2 | | |

Comments/Special Instructions: